

SPOKANE COUNTY FIRE DISTRICT 9

Fire Hydrant Acceptance Test Report

*A separate acceptance test report form is required for each new hydrant installed
Questions? Contact Doug Bleeker or Dan Walsh at 466-4602*

STEP 1: Hydrant information

Primary hydrant location/address _____

Hydrant make _____ Hydrant year _____

Residual hydrant location/address _____

*Residual hydrant must be on the same water system and closer to the supply source than the primary hydrant

STEP 2: Static pressure reading from residual hydrant 2 ½" port (with no water flowing)

Static Pressure _____

STEP 3: Primary hydrant pitot pressures taken from each 2 ½" port with hydrant operating nut opened full up and both ports flowing wide open

Pitot pressure from 2 ½" port #1 _____

Pitot pressure from 2 ½" port #2 _____

STEP 4: Residual pressure at residual hydrant, while primary hydrant has both 2 ½" ports flowing wide open

Residual pressure _____

	OK	Needs Repair
Hydrant drains back		
No other malfunctions		
No rocks/material in water stream		

Additional Comments: _____

Testing Company _____

Inspector Signature _____ Date _____